



NOTES:

1. DIAMETER OF ROD STOCK MUST EXCEED WIDTH OF REGLET GAP.
2. FASTEN MEMBRANE TO SUBSTRATE 12 INCHES ON CENTER.
2. IF FLASHING MEMBRANE EXTENDS ABOVE FINAL GRADE,
METAL COUNTER FLASHING MUST BE PROVIDED

500-9-A REGLET FLASHING

500-9-B CAP FLASHING

500-9AB

VERTICAL TERMINATIONS



© 2011 CARLISLE CORPORATION