



NOTES:

1. REMOVE ALL LEAD AND OTHER FLASHING.
2. ALL BOOTS OR CLAMPS MUST BE IN PLACE TO PROVIDE CONSTANT COMPRESSION ON WATER CUT-OFF MASTIC.
3. HOLE IN MEMBRANE MUST EXCEED SIZE OF DRAIN PIPE.
4. SLOPE OF STRUCTURAL SLAB IS RECOMMENDED TO BE A MINIMUM OF 1/8 INCH PER FOOT FOR DRAINAGE.

B-6

DOUBLE DRAIN



© 1996 CARLISLE CORPORATION